

**BOARD OF HEALTH  
MINUTES  
APRIL 12, 2017**

This meeting was advertised in the Hunterdon County Democrat, notice posted in the Alexandria Township Municipal Office, and the Alexandria Township website ([www.alexandrianj.gov](http://www.alexandrianj.gov)) as required by the Open Public Meetings Act.

**Meeting Called to Order at 7:38 PM.**

**ROLL CALL:**

**PRESENT:** Chair Garay, Comm. Pfefferle, Mayor Abraham, Twp. Attorney Dragan

**ABESENT:** None

**ITEMS FOR DISCUSSION:**

- Hunterdon Humane Shelter Update

Chair Garay noted that there has been some activity at the shelter. The driveway was paved and a new mailbox was installed. Chair Garay spoke to a representative from St. Hubert's to see if they knew of any developments at the shelter and they are aware of none.

- Grundman Pesticide Complaint

No update

- Waiver of Everittstown United Methodist Church Annual Food License in the amount of \$250.00

Mayor Abraham made a motion, seconded by Comm. Pfefferle to waive the Annual Food License Fee for the Everittstown United Methodist Church.

**Roll Call: Aye: Garay, Abraham, Pfefferle**

**Nay: None**

**Abstain: None**

**Motion Carried**

- Septic System Waiver B-12, L-13 555 County Road 513

Nevitt Duveneck, PE was present for the above property. The Hunterdon County Health Department received a septic alteration design with the most recent revision date of March 16, 2017 by ND Engineering, LLC. for an existing 4 bedroom dwelling with no expansion. Mayor Abraham made a motion, seconded by Comm. Pfefferle to approve the following five waivers:

1. The existing septic tank will be only 50 feet from the existing well which does not meet the minimum 100 foot setback requirement according to Alexandria Township ordinance.
2. The proposed disposal bed will be only 10 feet from the property line which does not meet the minimum 20 foot setback requirement according to Alexandria Township.
3. The proposed disposal bed will be only 10 feet from the garage slab which does not meet the minimum setback requirement of 15 feet according to code.
4. The use of the soil permeability class rating test shall not be used in certain soils including sandy clay loam unless the results of test are confirmed by field in-situ test. An engineer is requesting a waiver from this requirement.
5. The proposed disposal bed is only 85 feet from the existing well on this property which does not meet the minimum 100 foot setback requirement by code. As per 7:9A-4.3, the distance can be reduced to 50 feet provided there is 50 feet of casing. Since the well is in the cellar way and is old, the engineer is proposing to install a Ultra Violet device on the well for added protection and a water test shall also be done after installation.

**Roll Call: Aye: Garay, Abraham, Pfefferle**

**Nay: None**

**Abstain: None**

**Motion Carried**

#### **APPROVAL OF MINUTES:**

- March 8, 2017-Board of Health Meeting

Mayor Pfefferle made a motion, seconded by Comm. Pfefferle to approve the above Board of Health Meeting Minutes.

**Roll Call: Aye: Garay, Abraham, Pfefferle**

**Nay: None**

**Abstain: None**

**Motion Carried**

#### **CORRESPONDENCE / ANNOUNCEMENTS:**

- Help Prevent a Drought Emergency by Conserving water....Please take a Free Toilet Leak Detection Tablet at the Municipal Office Lobby. A leaking toilet can waste up to 200 gallons of water per day. A quick and easy fix can help conserve water and save you money.
- Community Well Test Day is Saturday, April 22<sup>nd</sup> from 9 AM to 12 Noon at the Township Municipal Offices.
- Volunteers Needed: Stream Clean up on Saturday, April 15<sup>th</sup>. The Environmental Commission will be meeting at the Municipal Office at 8:45 AM (Raindate: April 22<sup>nd</sup>)

**COMMENTS FROM THE FLOOR:**

None

**MOTION TO ADJOURN:**

Mayor Abraham made a motion, seconded by Comm. Pfefferle to adjourn.

**Roll Call: Aye: Garay, Abraham, Pfefferle**

**Nay: None**

**Abstain: None**

**Motion Carried**

**Meeting Adjourned at 7:48 PM.**

---

**Michele Bobrowski**  
**Board Secretary**